



NOTES

- 1) This drawing is for illustration purposes only and is subject to change without notice. TIC is not responsible for any errors or omissions.
- 2) A Maximum of 2 transformers can be equipped within the standard UPS cabinet.
- 3) An output transformer is not equipped in models with 208/120V output.

Drawn by
EO
DATE 03/25/04
Approved by
JIS
DATE 03/25/04

TOSHIBA
INTERNATIONAL CORPORATION
Houston Texas, USA

THIS MATERIAL IS THE EXCLUSIVE PROPERTY OF
TOSHIBA INTERNATIONAL CORPORATION AND SHALL NOT
BE REPRODUCED, USED, OR DISCLOSED TO OTHERS
UNLESS PRIOR WRITTEN AUTHORIZATION IS OBTAINED.

TITLE One-Line Drawing 4200FA XT2 UPS, 15 kVA Capacity Single Input Transformer Model, shown with External Bypass Transformer and External 2-Breaker Maintenance Bypass Switch	
DRAWING NO. T42X3X150XAMXN	REV. 1.2